



This publication contains the installation, operation and maintenance instructions for standard units of the *IMH-Industrial Material Handler*.



Carefully read this publication and any supplemental documents prior to any installation or maintenance procedure.

Loren Cook catalog, *IMH*, provides additional information describing the equipment, fan performance, available accessories and specification data.

For additional safety information, refer to AMCA Publication 410-96, *Safety Practices for Users and Installers of Industrial and Commercial Fans*.

All of the publications listed above can be obtained from:

- lorencook.com
- info@lorencook.com
- 417-869-6474 ext. 166

For information on special equipment, contact Loren Cook Company Customer Service Department at 417-869-6474.



IMH

Receiving and Inspection

Carefully inspect the fan and accessories for any damage and any shortage of accessories immediately upon receipt of the fan.

- Turn the wheel by hand to ensure it turns freely and does not bind.
- Inspect dampers (if supplied) for free operation of all moving parts.
- Record on the *Delivery Receipt* any visible sign of damage.

!WARNING

Rotating Parts & Electrical Shock Hazard:

Fans should be installed and serviced by qualified personnel only.

Disconnect electric power before working on unit (prior to removal of guards or entry into access doors).

Follow proper lockout/tagout procedures to ensure the unit cannot be energized while being installed or serviced.

A disconnect switch should be placed near the fan in order that the power can be swiftly cut off, in case of an emergency and in order that maintenance personnel are provided complete control of the power source.

Grounding is required. All field-installed wiring must be completed by qualified personnel. All field installed wiring must comply with National Electric Code (NFPA 70) and all applicable local codes.

Fans and blowers create pressure at the discharge and vacuum at the inlet. This may cause objects to get pulled into the unit and objects to be propelled rapidly from the discharge. The discharge should always be directed in a safe direction and inlets should not be left unguarded. Any object pulled into the inlet will become a projectile capable of causing serious injury or death.

When air is allowed to move through a non-powered fan, the impeller can rotate, which is referred to as windmilling. Windmilling will cause hazardous conditions due to unexpected rotation of components. Impellers should be blocked in position or air passages blocked to prevent draft when working on fans.

Friction and power loss inside rotating components will cause them to be a potential burn hazard. All components should be approached with caution and/or allowed to cool before contacting them for maintenance.

Under certain lighting conditions, rotating components may appear stationary. Components should be verified to be stationary in a safe manner, before they come into contact with personnel, tools or clothing.

Failure to follow these instructions could result in death or serious injury.

The attachment of roof mounted fans to the roof curb as well as the attachment of roof curbs to the building structure must exceed the structural requirements based on the environmental loading derived from the applicable building code for the site. The local code official may require variations from the recognized code based on local data. The licensed engineer of record will be responsible for prescribing the correct attachment based on construction materials, code requirements and environmental effects specific to the installation.

Handling

Lift the fan by the base or lifting eyes. Never lift by the shaft, motor or housing.

Storage

If the fan is stored for any length of time prior to installation, completely fill the bearings with grease or moisture-inhibiting oil (refer to *Lubricants*, page 6). Also, store the fan in its original crate and protect it from dust, debris and the weather.

Outdoor Storage

To protect unit from damage when lifting, the lifting straps and spreader bars should be utilized as shown in the figure below. To prevent scratching of the exterior surface, pads should be placed between the cabinet and the cables.

To maintain good working condition of the fan when it is stored outdoors, follow the additional instructions below.

- Coat the shaft with grease or a rust preventative compound.
- Wrap bearings for weather protection
- Cover the inlet and outlet of the fan to prevent the accumulation of dirt and moisture in the housing.
- Periodically rotate the wheel and operate dampers (if supplied).
- Periodically inspect the unit to prevent damaging conditions.

Installation

Most motors are shipped mounted on the fans with belts and drives installed. However, extremely heavy motors and drives are shipped separately. These motors and drives will require field installation. Please refer to pages tk 3-5.

Foundation

This fan requires a strong, level foundation of reinforced poured concrete. A correctly designed concrete foundation provides the best means for mounting floor units. The foundation's size is determined by fan size, motor size and position, and the specific location of the installation.

Use the following guidelines to calculate foundation size:

- The overall dimensions of the foundation should extend at least 6 inches beyond the outline of the fan and its motor.
- The weight of the foundation should be 2 to 3 times the weight of the unit and its motor.

Isolation

Isolation Base


To prevent vibration and noise from being transferred to the building isolators are recommended. Arrangement 1 fans require an isolation base to effectively isolate the fan system: fan, base, motor, drive, guards, etc. Bases must have sufficient rigidity to resist belt pull and prevent drive distortion which can lead to excessive belt and bearing wear; its perimeter should contain all base angles and rotating parts. Arrangement 10 fans above size 270 require isolation rails. Please consult factory for isolation of arrangement 9 fans due to the potential of uneven loading caused by the motor and drives. Isolators should be located between the fan system and the support structure.

NOTICE! Although a certain amount of vibration is inherent in operating centrifugal fans, extreme vibration is a serious problem that may cause structural and mechanical failure.


Ceiling Mounted Isolators

Some applications require fan systems, designed for floor mounting, suspended from ceiling supports. In such cases, IMH fans of all arrangements should be installed on either rails or bases in the classical orientation. Typically, these systems are hung from the corners by rods, which include isolation hangers of either spring or rubber-in-shear design.

Under no circumstances is the fan to be inverted and hung by its base angles.



Ceiling Mounted Spring Isolator



Rubber-in-Shear Ceiling Isolator


Figure 1- Ceiling Mount Isolators

Floor Mounted Spring Isolators


- Mount fan and motor on isolation base (if supplied).
- Elevate fan (or isolation base) to operating height and insert blocks to hold in position.
- Position isolators under the fan (or isolation base) and vertically align by inserting leveling bolt through mounting holes in the fan or the base. The isolator must be installed on a level surface.
- Adjust the isolators by turning the leveling nut counter clockwise several turns at a time alternately on each isolator until the fan weight is transferred onto the isolators and the fan raises uniformly off the blocks. Then remove the blocks.
- Turn lock nut onto leveling bolt and secure firmly in place against the top of the mounting flange or frame.
- Secure isolators to mounting surface.

Floor Mounted Rubber-In-Shear (RIS) Isolators

- Mount fan and motor on an isolation base (if supplied).
- Elevate fan to provide room to insert isolators between the fan and foundation and block in position.
- Position isolators under fan and secure bolts.
- Remove blocks and allow fan to rest on floor. Isolators must be installed on a level surface (leveling should not be required).
- Secure isolators to mounting surface.



Spring Isolator



Rubber-in-Shear Isolator


Figure 2- Floor Mount Isolators

Duct Installation

Efficient fan performance relies on the proper installation of inlet and discharge ducts. Be sure your fan conforms to the guidelines below.


Non-Ducted Inlet Clearance

If your fan has an open inlet (no duct work), the fan must be placed 1 fan wheel diameter away from walls and bulkheads. An inlet bell should be used in this case.



Free Discharge


Avoid a free discharge into the plenum. This will result in lost efficiency because it doesn't allow for a static regain.



Free Discharge

Inlet Duct Turns


For ducted inlets, allow at least 3 fan wheel diameters between duct turns or elbows and the fan inlet.



Inlet Duct Turns

Discharge Duct Turns

Make sure that duct turns located near the fan discharge curve in the direction of the fan's rotation. Refer to the Discharge Duct Turns illustration.



Discharge Duct Turns

Wheel-to-Inlet Clearance

The correct wheel-to-inlet clearance is critical to proper fan performance. This clearance should be verified before initial start-up since rough handling during shipment could cause a shift in fan components. Refer to wheel/inlet drawing below for correct clearance. Adjust the overlap by loosening the wheel hub and moving the wheel along the shaft to obtain the correct value.

Size	Wheel-to-Inlet Clearance and Overlap			
	MH, MHB, MHR		MHA	
	Wheel-to-Inlet Ring Clearance	Wheel-to-Inlet Ring Overlap	Min.	Max.
70	3/16	5/16	1/8	1/4
90	3/16	5/16	1/8	4/4
110	3/16	5/16	3/16	5/16
130	3/16	5/16	1/4	3/8
150	3/16	5/16	1/4	3/8
170	3/16	5/16	5/16	7/16
190	3/16	5/16	3/8	1/2
210	5/16	7/16	7/16	9/16
230	5/16	7/16	7/16	9/16
260	5/16	7/16	1/2	5/8
290	5/16	7/16	5/8	3/4

Wiring Installation

All wiring should be in accordance with local ordinances and the National Electrical Code, NFPA 70. Ensure the power supply (voltage, frequency, and current carrying capacity of wires) is in accordance with the motor name-plate.

Lock off all power sources before unit is wired to power source.

Leave enough slack in the wiring to allow for motor movement when adjusting belt tension. Some fractional motors have to be removed in order to make the connection with the terminal box at the end of the motor. To remove motor, remove bolts securing motor base to power assembly. Do not remove motor mounting bolts.

Follow the wiring diagram in the disconnect switch and the wiring diagram provided with the motor. Correctly label the circuit on the main power box and always identify a closed switch to promote safety (i.e., red tape over a closed switch).

Wheel Rotation

Test the fan to ensure the rotation of the wheel is the same as indicated by the arrow marked Rotation.

115 and 230 Single Phase Motors

Fan wheel rotation is set correctly at the factory. Changing the rotation of this type of motor should only be attempted by a qualified electrician.


208, 230, and 460, 3 Phase Motors

These motors are electrically reversible by switching two of the supply leads. For this reason, the rotation of the fan cannot be restricted to one direction at the factory. See *Wiring Diagrams on page tk (4) for specific information on reversing wheel direction.*

Do not allow the fan to run in the wrong direction. This will overheat the motor and cause serious damage. For 3-phase motors, if the fan is running in the wrong direction, check the control switch. It is possible to interchange two leads at this location so that the fan is operating in the correct direction.

Belt and Pulley Installation

Figure 3



Belt tension is determined by the sound of the belts when the fan is first started. The belts will produce a loud squeal, which dissipates after the fan is operating at full capacity. If belt tension is too tight or too loose, lost efficiency and damage can occur.

Do not change the pulley pitch diameter to change tension. The change will result in a different fan speed.

1. Loosen the motor plate adjustment nuts on motor base and move motor plate in order that the belts can easily slip into the grooves on the pulleys. Never pry, roll, or force the belts over the rim of the pulley.
2. Adjust the motor plate until proper tension is reached. For proper tension, a deflection of approximately 1/4" per foot of center distance should be obtained by firmly pressing the belt. Refer to *Figure 3*.
3. Lock the motor plate adjustment nuts in place.
4. Ensure pulleys are properly aligned. Refer to *Figure 4*.

Use of Variable Frequency Drives

Motors

Motors that are to be operated using a Variable Frequency Drive (VFD) must be VFD compatible. At a minimum, this must be a Premium Efficiency motor with Class F insulation. Motors that are not supplied by Loren Cook Company should have the recommendation of the motor manufacturer for use with a VFD.

Grounding

The fan frame, motor and VFD must be connected to a common earth ground to prevent transient voltages from damaging rotating elements.

Wiring


Line reactors may be required to reduce over-voltage spikes in the motors. The motor manufacturer should be consulted for recommended line impedance and usage of line reactors or filters, if the lead length between the VFD and the motor exceeds 10 feet (3m).

Fan

It is the responsibility of the installing body to perform coast-down tests and identify any resonant frequencies after the equipment is fully installed. These resonant frequencies are to be removed from the operating range of the fan by using the "skip frequency" function in the VFD programming. Failure to remove resonant frequencies from the operating range will decrease the operating life of the fan and void the warranty.


Wiring Diagrams

Single Speed, Single Phase Motor




When ground is required, attach to ground A or B with No. 6 thread forming screw. To reverse, interchange T-1 and T-4.

2 Speed, 2 Winding, Single Phase Motor



When ground is required, attach to ground A or B with No. 6 thread forming screw. To reverse, interchange T-1 and T-4 leads.


Single Speed, Single Phase, Dual Voltage




When ground is required, attach to ground A or B with No. 6 thread forming screw. To reverse, interchange T-5 and J-10 leads.

3 Phase, 9 Lead Motor

3 Phase, 9 Lead Motor Y-Connection




3 Phase, 9 Lead Motor Delta-Connection




To reverse, interchange any 2 line leads.

2 Speed, 1 Winding, 3 Phase Motor




To reverse, interchange any 2 line leads. Motors require magnetic control.

2 Speed, 2 Winding, 3 Phase



To reverse: High Speed-interchange leads T_{11} and T_{12} . Low Speed-interchange leads T_1 and T_2 . Both Speeds-interchange any 2 line leads.

Typical Damper Motor Schematic



For 3 Phase, damper motor voltage should be the same between L_1 and L_2 . For single phase application, disregard L_3 . *Damper motors may be available in 115, 230 and 460 volt models. The damper motor nameplate voltage should be verified prior to connection. **A transformer may be provided in some installations to correct the damper motor voltage to the specified voltage.

Pulley Alignment

Pulley alignment is adjusted by loosening the motor pulley setscrew and by moving the motor pulley on the motor shaft.

Figure 4 indicates where to measure the allowable gap for the drive alignment tolerance. All contact points (indicated by WXYZ) are to have a gap less than the tolerance shown in the *Tolerance* table.

When the pulleys are not the same width, the allowable gap must be adjusted by half of the difference in width. Figure 5 illustrates using a carpenter's square to adjust the position of the motor pulley until the belt is parallel to the longer leg of the square.

Tolerance

Center Distance	Max. Gap
Up thru 12"	1/16"
12" up through 48"	1/8"
Over 48"	1/4"




Figure 4

Final Installation Steps

1. Inspect fasteners and setscrews (particularly fan mounting and bearing fasteners) and tighten according to the recommended torque shown in the table *Recommended Torque for Setscrews/Bolts*.
2. Inspect for correct voltage with voltmeter.
3. Ensure all accessories are installed.

Operation

Pre-Start Checks

1. Lock out all the primary and secondary power sources.
2. Ensure fasteners and setscrews, particularly those used for mounting the fan, are tightened.
3. Inspect belt tension and pulley alignment.
4. Inspect belt tension on energy wheel drive belt.
5. Inspect motor wiring.
6. Ensure belt touches only the pulley.
7. Ensure fan and ductwork are clean and free of debris.
8. Inspect wheel-to-inlet clearance. The correct wheel-to-inlet clearance is critical to proper fan performance.
9. Close and secure all access doors.
10. Restore power to the fan.

Start-Up

Turn the fan on. In variable speed units, set the fan to its lowest speed and inspect for the following:

- Direction of rotation.
- Excessive vibration.
- Unusual noise.
- Bearing noise.
- Improper belt alignment or tension (listen for squealing).
- Improper motor amperage or voltage.




Figure 5

NOTICE! If a problem is discovered, immediately shut off the fan. Lock out all electrical power and check for the cause of the trouble. Refer to *Troubleshooting*.

Recommended Torque for Setscrews/Bolts (in/lb)

Size	Key Hex Across Flats	Recommended Torque		Hold Down Bolts	
		Min.	Max.	Size	Wrench Torque
No. 10	3/32"	28	33	3/8"-16	240
1/4"	1/8"	66	80	1/2"-13	600
5/16"	5/32"	126	156	5/8"-11	1200
3/8"	3/16"	228	275	3/4"-10	2100
7/16"	7/32"	348	384	7/8"-9	2040
1/2"	1/4"	504	600	1"-8	3000
5/8"	5/16"	1104	1200	1-1/8"-7	4200
3/4"	3/8"	1440	1800	1-1/4"-7	6000

Inspection

Inspection of the fan should be conducted at the first 30 minute, 8 hour and 24 hour intervals of satisfactory operation. During the inspections, stop the fan and inspect as per the *Conditions Chart*.

30 Minute Interval

Inspect bolts, setscrews and motor mounting bolts. Adjust and tighten as necessary.

8 Hour Interval

Inspect belt alignment and tension. Adjust and tighten as necessary.

24 Hour Interval

Inspect belt tension on both blowers and energy wheel drive belt. Adjust and tighten as necessary.

Maintenance

Establish a schedule for inspecting all parts of the fan. The frequency of inspection depends on the operating conditions and location of the fan.

Inspect fans exhausting corrosive or contaminated air within the first month of operation. Fans should be inspected every three months.

Regular inspections are recommended for fans exhausting non-contaminated air.

It is recommended the following inspection be conducted twice per year.

- Inspect bolts and setscrews for tightness. Tighten as necessary. Worn setscrews should be replaced immediately.
- Inspect belt wear and alignment. Replace worn belts with new belts and adjust alignment as needed. Refer to *Belt and Pulley Installation*, page tk (3).
- Bearings should be inspected as recommended in the *Conditions Chart*.
- Inspect variable inlet vanes for freedom of operation and excessive wear. The vane position should agree with the position of the control arm. As the variable inlet vanes close, the entering air should spin in the same direction as the wheel.
- Inspect springs and rubber isolators for deterioration and replace as needed.
- Inspect for cleanliness. Clean exterior surfaces only. Removing dust and grease on motor housing assures proper motor cooling. Removing dirt from the wheel and housing prevent imbalance and damage.

Lubrication - Fan Bearings

Greaseable fan bearings are lubricated through a grease fitting on the bearing and should be lubricated by the schedule, *Conditions Chart*.

Conditions Chart			
Fan Class	Fan Status	Shaft Size	Max. Interval (operational hrs)
Standard Duty	Normal Conditions (Clean, Dry & Smooth)	> 2"	7,500
		< 2"	1,000
	Extreme Conditions (Dirty/Wet/Rough)	> 2"	1,500
		< 2"	200
Heavy Duty	Normal Conditions (Clean, Dry & Smooth)	> 2"	3,000
		< 2"	500
	Extreme Conditions (Dirty/Wet/Rough)	> 2"	500
		< 2"	100

For best results, lubricate the bearing while the fan is in operation. Pump grease in slowly until a slight bead forms around the bearing seals. Excessive grease can burst seals thus reducing bearing life.

In the event the bearing cannot be seen, use no more than three injections with a hand-operated grease gun.

Before lubricating, the grease nipple and immediate vicinity should be thoroughly cleaned without the use of high pressure equipment. The grease should be supplied slowly as the bearing rotates until fresh grease slips past the seal. Excessive pressure should be avoided to prevent seal damage.

Exceptions to the greasing interval chart:

Periodic Applications (any break of one week of more)

It is recommended that the full lubrication be performed prior to each break in operation.

Higher Temperature

It is recommended to halve the intervals for every 30°F increase in operating temperature above 120°F not to exceed 230°F for standard bearings; High Temperature bearings (optional) can operate up to 400°F.

Vertical Shaft

It is recommended that the intervals should be halved.

Loren Cook Company uses petroleum lubricant in a lithium base. Other types of grease should not be used unless the bearings and lines have been flushed clean. If another type of grease is used, it should be a lithium-based grease conforming to NLGI grade 2 consistency.

A NLGI grade 2 grease is a light viscosity, low-torque, rust-inhibiting lubricant that is water resistant. Its temperature range is from -30°F to +200°F and capable of intermit-tent highs of +250°F. For temperatures above 250°F, Mobiltemp SHC 32 is recommended.

Lubrication - Motor Bearings

Motors are provided with prelubricated bearings. Any lubrication instructions shown on the motor nameplate supersede instructions below.

Motor bearings without provisions for relubrication will operate up to 10 years under normal conditions with no maintenance. In severe applications, high temperatures or excessive contaminants, it is advisable to have the maintenance department disassemble and lubricate the bearings after 3 years of operation to prevent interruption of service.

For motors with provisions for relubrication, follow intervals of the following table.

Service Conditions	Relubrication Intervals					
	NEMA Frame Size					
	Up to and Including 184T		213T-365T		404T and Larger	
	1800 RPM and less	Over 1800 RPM	1800 RPM and Less	Over 1800 RPM	1800 RPM and less	Over 1800 RPM
Standard	3 yrs.	6 months	2 yrs.	6 months	1 yr.	3 months
Severe	1 yr.	3 months	1 yr.	3 months	6 months	1 month

Motors are provided with a polyurea mineral oil NGLI #2 grease. All additions to the motor bearings are to be with a compatible grease such as Exxon Mobil Polyrex EM and Chevron SRI.

The above intervals should be reduced to half for vertical shaft installations.

Maximum RPM

Size	Maximum RPM		Size	Maximum RPM	
	SD*	HD**		SD*	HD**
70	3742	6236	190	1389	2315
90	2934	4889	210	1256	2093
110	2397	3994	230	1146	1910
130	2026	3377	260	1016	1693
150	1755	2924	290	908	1513
170	1547	2579			

Unless otherwise noted, wheel construction for standard duty and heavy duty is the same. *Standard duty. **Heavy duty.

Motor Services

Should the motor prove defective within a one-year period, contact your local Loren Cook representative or your nearest authorized electric motor service representative.

Changing Shaft Speed

All belt driven ventilators (5HP or less) are equipped with variable pitch pulleys. To change fan speed, perform the following:

1. Loosen setscrew on driver (motor) pulley and remove key, if equipped.
2. Turn the pulley rim to open or close the groove facing. If the pulley has multiple grooves, all must be adjusted to the same width.
3. After adjustment, inspect for proper belt tension.

Speed Reduction

Open the pulley in order that the belt rides deeper in the groove (smaller pitch diameter).

Speed Increase

Close the pulley in order that the belt rides higher in the groove (larger pitch diameter). Ensure that the RPM limits of the fan and the horsepower limits of the motor are maintained.

Replacing Fan Pulleys and Belts

1. Remove pulleys from their respective shafts.
2. Clean the motor and fan shafts.
3. Clean bores of pulleys and coat the bores with heavy oil.
4. Remove grease, rust, or burrs from the pulleys and shafts.
5. Remove burrs from shaft by sanding.
6. Place fan pulley on fan shaft and motor pulley on its shaft. Damage to the pulleys can occur when excessive force is used in placing the pulleys on their respective shafts.
7. Tighten in place.
8. Install belts on pulleys and align as described in the *Belt and Pulley Installation* section.

RPM Derating Factor

Steel		Aluminum	
Temp.°F	RPM	Temp.°F	RPM
70	1.00	70	1.00
200	.98	200	.93
300	.96	300	.79
400	.94		
500	.91		
600	.87		
700	.81		
800	.75		

For elevated airstream temperatures, the maximum RPM limits must be derated by the factors found in the tables above.

Bearing Replacement

The fan bearings are pillow block ball bearings. Bearings should be replaced individually from each side of fan.

An emery cloth or file may be needed to remove imperfections in the shaft left by the setscrews.

1. Mark the position on the shaft of both bearing races, setscrews, and the wheel and pulley. Note the clearance between the wheel and inlet.
2. Remove the fan pulley and belts.
3. Remove the inlet side panel by removing the bolts around the perimeter of panel.
4. Remove inlet cone by removing attaching bolts/nuts around perimeter of the inlet plate.
5. Remove wheel from the shaft. A 2-jaw puller may be needed.
6. Remove bearing hold-down bolts. Remove shaft and bearings as one unit.
7. Remove anti-corrosion coating from the shaft with a suitable degreaser.
8. Remove the bearing from the shaft using a bearing puller.

If a bearing puller is not available, tap on the bearing with a wood block and hammer to remove it.

9. Smooth and clean the shaft and bearing bore thoroughly.
10. Place the bearings into position making sure they are not on a worn section of the shaft. Tapping the inner ring face with a soft driver may be required.

Do not hammer on the housing.

11. The outer ring of the bearing is spherical and swivels in the housing to compensate for misalignment. Secure hold-down bolts, but do not fully tighten.
12. Align the setscrews on the bearings and tighten one setscrew on each bearing.
13. Rotate the shaft to allow the bearing outer rings to find their center of free movement.
14. Install the wheel on the shaft and install the inlet side panel in its original location. Adjust bearing position and inlet side panel to center the wheel in the inlet.
15. Tighten bearing hold-down bolts to proper torque. Refer to *Torque Chart*.
16. Turn the shaft by hand. Resistance should be the same as it was before hold-down bolts were fully tightened.
17. Tighten bearing setscrews to specified torque as noted in the *Torque Chart*.
18. Reinstall the pulley and adjust the belt tension. Refer to *Belt and Pulley Installation*.
19. Test run the fan and trim balance as necessary (.0785 in/sec max.).
20. Re-tighten setscrews on bearings, sheave, and wheel. Recheck belt tension and adjust as needed.

Troubleshooting

Problem and Potential Cause

Low Capacity or Pressure:

- Incorrect direction of rotation. Make sure the fan rotates in same direction as the arrows on the motor or belt drive assembly.
- Poor fan inlet conditions. There should be a straight clear duct at the inlet.
- Improper propeller alignment.

Excessive Vibration and Noise:

- Damaged or unbalanced propeller.
- Belts too loose; worn or oily belts.
- Speed too high.
- Incorrect direction of rotation. Make sure the fan rotates in same direction as the arrows on the motor or belt drive assembly.
- Bearings need lubrication or replacement.
- Fan surge or inlet or outlet conditions.

Overheated Motor:

- Motor improperly wired.
- Incorrect direction of rotation. Make sure the fan rotates in same direction as the arrows on the motor or belt drive assembly.
- Cooling air diverted or blocked.
- Improper inlet clearance.
- Incorrect fan RPMs.
- Incorrect voltage.


Overheated Bearings:

- Improper bearing lubrication
- Excessive belt tension.

Parts List


Arrangement 1

Part No.	Sizes 70-290	Part No.	Sizes 70-290
1	Motor slide Base (optional)	9	Drive Side Bearing
2	Motor Sheave	10	Shaft Guard (optional)
3	Motor	11	Opposite Drive Side Bearing
4	Belt Set	12	Wheel
5	Fan Sheave	13	Inlet Side Panel
6	Housing	14	Spreader Bar (2)
7	Shaft	15	Bearing Pedestal
8	Belt Guard	16	Isolation Base (optional)




Arrangement 8

Part No.	Sizes 70-290	Part No.	Sizes 70-290
1	Housing	7	Opposite Drive Side Bearing
2	Motor	8	Wheel
3	Optional Coupling Guard	9	Inlet Side Panel
4	Drive Side Bearing	10	Spreader Bar (2)
5	Shaft	11	Motor/Bearing Pedestal
6	Shaft Guard (optional)		




Arrangement 9

Part No.	Sizes 70-290	Part No.	Sizes 70-290
1	Motor Sheave	9	Shaft Guard (optional)
2	Motor Cover (optional)	10	Opposite Drive Side Bearing
3	Belt Set	11	Wheel
4	Fan Sheave	12	Inlet Side Panel
5	Housing	13	Spreader Bar (2)
6	Shaft	14	Bearing Pedestal
7	Belt Guard (optional)	15	Motor Slide Base
8	Drive Side Bearing	16	Motor



Arrangement 10 (available in SD only)

Part No.	Sizes 70-290	Part No.	Sizes 70-290
1	Motor Sheave	8	Opposite Drive Side Bearing
2	Belt Set	9	Wheel
3	Fan Sheave	10	Inlet Side Panel
4	Housing	11	Spreader Bar (2)
5	Shaft	12	Bearing Pedestal
6	Weather Cover/ Belt Guard	13	Motor Mount Assembly
7	Drive Side Bearing	14	Motor



Limited Warranty

Loren Cook Company warrants that your Loren Cook fan was manufactured free of defects in materials and workmanship, to the extent stated herein. For a period of one (1) year after date of shipment, we will replace any parts found to be defective without charge, except for shipping costs which will be paid by you. This warranty is granted only to the original purchaser placing the fan in service. This warranty is void if the fan or any part thereof has been altered or modified from its original design or has been abused, misused, damaged or is in worn condition or if the fan has been used other than for the uses described in the company manual. This warranty does not cover defects resulting from normal wear and tear. To make a warranty claim, notify Loren Cook Company, General Offices, 2015 East Dale Street, Springfield, Missouri 65803-4637, explaining in writing, in detail, your complaint and referring to the specific model and serial numbers of your fan. Upon receipt by Loren Cook Company of your written complaint, you will be notified, within thirty (30) days of our receipt of your complaint, in writing, as to the manner in which your claim will be handled. If you are entitled to warranty relief, a warranty adjustment will be completed within sixty (60) business days of the receipt of your written complaint by Loren Cook Company. This warranty gives only the original purchaser placing the fan in service specifically the right. You may have other legal rights which vary from state to state.



LOREN COOK COMPANY

Corporate Offices: 2015 E. Dale St. Springfield, MO 65803
 Phone 417-869-6474 | Fax 417-862-3820 | lorencook.com