



COOK Extended Mounting Flange

DATE: _____

PROJECT: _____

LOCATION: _____

SWB, SWD, AWB, AWD, HWB, EWB
 XLW, XMW, XLWH, XMWH
 XLP, XMP, XLPH, XMPH
 APD, APB, SPD, SPB
 Propeller Wall Fans

DIMENSION DATA

SWD,SWB,HWB AWD,AWB,XLW XMW,XLWH,XMWH XLP,XMP,XLPH,XMPH APD,APB,SPD,SPB Size	EWB Size	A Sq.	B Sq.	C Sq.	D	E	WO*	Galvanized Steel Gauge
8	-	12-1/8	21	10	12	16	12-7/8	14
10	-	16-3/16	25	14	14-3/8	18-3/4	17	14
12	-	16-3/16	25	14	14-3/8	18-3/4	17	14
14	-	20-3/16	29	18	15-3/8	21-3/4	21	14
16	-	20-3/16	29	18	15-3/8	21-3/4	21	14
18	-	24-3/16	33	22	17-5/8	24-1/2	25	14
20	-	24-3/16	33	22	17-5/8	24-1/2	25	12
24	-	30-3/16	37	28	18-3/4	27-1/4	31	12
30	24	36-3/16	43	34	18-3/4	31-1/2	37	12
36	30	42-3/16	49	40	19-1/2	35-3/4	43	12
42	36	48-3/16	55	46	19-1/2	40	49	12
48	42	54-3/16	61	52	19-3/4	44-1/4	55	12
54	48	60-3/16	67	58	19-3/4	48-1/2	61	12
60	54	66-3/16	73	64	19-3/4	52-3/4	67	12
-	60	72-3/16	79	70	19-3/4	57	73	12
-	72	84-3/16	91	82	19-3/4	67-7/16	85	12

ALL DIMENSIONS IN INCHES.

* THE WO (WALL OPENING) DIMENSION IS TO THE OUTSIDE OF THE FASTENERS.

* FASTENERS SHOULD BE PLACED ON 6" TO 10" CENTERS ON THE PERIMETER OF THE WALL COLLAR. WALL COLLAR SHOULD BE CAULKED TO THE EXTERIOR OF THE WALL.

NOTE: ALLOWS MOUNTING OF WEATHER HOOD TO WALL COLLAR OR WALL HOUSING.

