

Typical Specifications

Model: TRE

Description: Unit shall be an extruded aluminum, roof mounted gravity relief or intake ventilator.

Certifications: Fan shall be manufactured at an ISO 9001 certified facility.

Construction: The unit shall be manufactured of 0.081 gauge extruded aluminum tiers welded to a minimum 8 gauge aluminum support structure. The aluminum hood shall be constructed of minimum 0.063 aluminum and provided with a layer of anti-condensate coating. The aluminum base shall have continuously welded curb cap corners for maximum leak protection. Birdscreen constructed of 1/2" galvanized mesh shall be mounted across the relief opening. Unit shall bear an engraved aluminum nameplate. Nameplate shall indicate design CFM and static pressure. Unit shall be shipped in ISTA certified transit tested packaging.

Product: Unit shall be model TRE as manufactured by Loren Cook Company of Springfield, Missouri.

07/29/04