

Typical Specifications

Model: VI

Description: Unit shall be a hooded aluminum, roof mounted gravity intake ventilator.

Certifications: Fan shall be manufactured at an ISO 9001 certified facility.

Construction: The unit shall be of bolted and welded construction utilizing corrosion resistant fasteners. The aluminum hood shall be constructed of minimum 14 gauge marine alloy aluminum, bolted to a minimum 8 gauge aluminum support structure. The aluminum base shall have continuously welded curb cap corners for maximum leak protection. Birdscreen constructed of 1/2" mesh shall be mounted across the intake opening. Unit shall bear an engraved aluminum nameplate. Nameplate shall indicate design CFM and static pressure. Unit shall be shipped in ISTA certified transit tested packaging.

Product: Unit shall be model VI as manufactured by Loren Cook Company of Springfield, Missouri.

10/20/03