

Typical Specifications

Model: ASP-T

Description: Fan shall be a tiered aluminum hooded, roof mounted, belt driven, centrifugal filtered supply fan.

Certifications: Fan shall be manufactured at an ISO 9001 certified facility. Fan shall be listed by Underwriters Laboratories (UL 705) and UL listed for Canada (cUL 705). Fan shall bear the AMCA certified ratings seal for sound and air performance.

Construction: The fan shall be of bolted construction utilizing corrosion resistant fasteners. Hood shall be tiered extruded aluminum, bolted to a minimum 16 gauge steel fan base with prepunched mounting holes. Unit shall be provided with an insulated aluminum top cover and 1" washable permanent aluminum filters. Internal blower and motor assembly shall be mounted on rubber vibration isolators. Unit shall bear an engraved aluminum nameplate. Nameplate shall indicate design CFM, static pressure, and maximum fan RPM. Unit shall be shipped in ISTA certified transit tested packaging.

Wheel: Wheel shall be steel, centrifugal forward curved type. Wheel shall utilize an aerodynamic aluminum inlet cone to provide maximum performance and efficiency. Wheel shall be balanced in accordance with AMCA Standard 204-05, *Balance Quality and Vibration Levels for Fans*.

Motor: Motor shall be Nema design B with class B insulation rated for continuous duty and furnished at the specified voltage, phase and enclosure.

Bearings: Bearings shall be ball type selected for a minimum L50 life in excess of 200,000 hours at maximum cataloged operating speed.

Belts and Drives: Belts shall be oil and heat resistant, static conducting. Drives shall be precision machined cast iron type, keyed and securely attached to the wheel and motor shafts. Drives shall be sized for 150% of the installed motor horsepower. The variable pitch motor drive must be factory set to the specified fan RPM.

Product: Fan shall be model ASP-T as manufactured by Loren Cook Company of Springfield, Missouri.