

Typical Specifications

Model: CVR

Description: Fan shall be a spun aluminum, hooded, roof mounted, belt driven, tubular centrifugal exhaust fan.

Certifications: Fan shall be manufactured at an ISO 9001 certified facility. Fan shall be listed by Underwriters Laboratories (UL 705) and UL listed for Canada (cUL 705).

Construction: The fan shall be bolted and welded construction utilizing corrosion resistant fasteners. The spun aluminum housing shall be constructed of minimum 11 gauge marine alloy aluminum with inlet and outlet flanges. The spun aluminum top cap shall be constructed of minimum 0.050" thick marine alloy aluminum, and the aluminum base shall have continuously welded curb cap corners for maximum leak protection. Straightening vanes shall be utilized for uniform airflow. Extended lube lines shall be furnished for lubrication of fan bearings. Aluminum adjustable motor mounting plate shall utilize threaded studs for positive belt tensioning. An aluminum weatherproof motor cover shall be standard. Unit shall bear an engraved aluminum nameplate. Nameplate shall indicate design CFM, static pressure, and maximum fan RPM. Unit shall be shipped in ISTA certified transit tested packaging.

Wheel: Wheel shall be a non-overloading design utilizing airfoil blades for maximum efficiency. The aluminum airfoil blades shall be continuously welded to a spun aluminum dome. The dome shall be bolted to a cast or heavy gauge aluminum hub assembly. The hub shall be keyed and secured to the fan shaft with two set screws. Wheel shall be balanced in accordance with AMCA Standard 204-05, *Balance Quality and Vibration Levels for Fans*.

Motor: Motor shall be Nema design B with class B insulation rated for continuous duty and furnished at the specified voltage, phase and enclosure.

Bearings: Bearings shall be designed and tested specifically for use in air handling applications. Construction shall be heavy duty regreasable ball type in a cast iron housing selected for a minimum L50 life in excess of 200,000 hours at maximum cataloged operating speed.

Belts and Drives: Belts shall be oil and heat resistant, static conducting. Drives shall be precision machined cast iron type, keyed and securely attached to the wheel and motor shafts. Drives shall be sized for 150% of the installed motor horsepower. The variable pitch motor drive must be factory set to the specified fan RPM.

Product: Fan shall be model CVR as manufactured by Loren Cook Company of Springfield, Missouri.