

# Typical Specifications

**Model:** GC 100 Series

**Description:** Fan shall be ceiling mounted, direct driven, centrifugal exhaust fan.

**Certifications:** Fan shall be manufactured at an ISO 9001 certified facility. Fan shall be listed by Underwriters Laboratories (UL 705) and UL listed for Canada (cUL 705). Fan shall bear the AMCA Certified Ratings Seal for Sound and Air Performance.

**Construction:** The fan wheel housing and integral outlet duct shall be injection molded from a specially engineered resin exceeding UL requirements for smoke and heat generation. The outlet duct shall have provision for an aluminum backdraft damper with continuous aluminum hinge rod. The inlet box shall be minimum 22 gauge galvanized steel. Motor shall be isolation mounted to a one piece galvanized stamped steel integral motor mount/inlet. A field wiring compartment with disconnect receptacle shall be standard. To accommodate different ceiling thickness, an adjustable prepunched mounting bracket shall be provided. A white, non-yellowing, high impact styrene injection molded designer style grill shall be provided as standard. Unit shall be designed with provision for field conversion from ceiling to in-line. Unit shall be shipped in ISTA Certified Transit Tested Packaging.

**Wheel:** Wheel shall be centrifugal forward curved type, injection molded of polypropylene resin. Wheel shall be balanced in accordance with AMCA Standard 204-05, Balance Quality and Vibration Levels for Fans.

**Motor:** Motor shall be open drip proof type with permanently lubricated bearings and include impedance or thermal overload protection and disconnect plug. Motor shall be furnished at the specified voltage.

**Product:** Fan shall be GC 120-180 as manufactured by Loren Cook Company of Springfield, Missouri.