

# Typical Specifications

**Model:** HXFL

**Description:** Fan shall be a low profile, hooded, roof mounted, belt driven, low pressure, filtered propeller supply ventilator.

**Certifications:** Fan shall be manufactured at an ISO 9001 certified facility. Fan shall be listed by Underwriters Laboratories (UL 705) and UL listed for Canada (cUL 705). Fan shall bear the AMCA certified ratings seal for air performance.

**Construction:** The fan shall be of bolted and welded construction utilizing corrosion resistant fasteners. The motor, bearings and drives shall be mounted on a welded tubular steel power assembly. The power assembly shall be rigidly secured to the fan housing. The powder coated steel fan housing shall include a minimum 14 gauge base with integral spun venturi and continuously welded curb cap corners. The fan shall be enclosed with a minimum 18 gauge galvanized steel hood bolted to the fan housing. The hood shall have a removable top cap to allow unobstructed access to the motor and power assembly without removing entire hood. Filters shall be washable expanded aluminum media with two inch formed aluminum frame. Unit shall bear an engraved aluminum nameplate. Nameplate shall indicate design CFM, static pressure, and maximum fan RPM. Unit shall be shipped in ISTA certified transit tested packaging.

**Coating:** All non-galvanized steel fan components shall be Lorenized™ with an electrostatically applied, baked polyester powder coating. Each component shall be subject to a five stage environmentally friendly wash system, followed by a minimum 2 mil thick baked powder finish. Paint must exceed 1,000 hour salt spray under ASTM B117 test method.

**Propeller:** Propeller shall be a high-efficiency fabricated steel design with blades securely fastened to a minimum 7 gauge steel hub. The hub shall be keyed and locked to the fan shaft utilizing two setscrews. Propeller shall be balanced in accordance with AMCA Standard 204-05, *Balance Quality and Vibration Levels for Fans*.

**Motor:** Motor shall be NEMA design B with class B insulation rated for continuous duty and furnished at the specified voltage, phase and enclosure.

**Bearings:** Bearings shall be designed and tested specifically for use in air handling applications. Construction shall be heavy duty regreasable ball type in a cast iron housing selected for a minimum L50 life in excess of 200,000 hours at maximum cataloged operating speed.

**Belts and Drives:** Belts shall be oil and heat resistant, static conducting. Drives shall be precision machined cast iron type, keyed and securely attached to the wheel and motor shafts. Drives shall be sized for 150% of the installed motor horsepower. The variable pitch motor drive must be factory set to the specified fan RPM.

**Product:** Fan shall be the HXFL as manufactured by Loren Cook Company of Springfield, Missouri.